

Partition panels Surgical

## INSTALLATION SYSTEM FOR OPERATING ROOMS - UPPER MODULE



The base panels form the final surface of the entire partition system. The system is horizontally divided into three parts:

- **Lower part** is supplied in AISI 304 version or with a powder-coated surface finish according to the customer's wishes.
- **Middle demountable part** is typically color-contrasted from the remaining panels according to the color scheme of the entire room.
- **Upper part** is usually supplied in the same color scheme as the suspended ceiling in the operating rooms.

## PRODUCT DESCRIPTION

- Height is dependent on the clear height of the medical space (operating room).
- Items such as analog clocks, the upper grille of the exhaust duct, or signal signs are built into it.
- There is sufficient space in the partition for the distribution of media, ventilation, and electrical power lines.
- The hermeticity of the system is ensured by sealing or with an inserted gasket.
- The individual panels are conductively connected to each other.
- The wall system meets the requirements for airborne sound insulation.

**Distribution of the Surgical partition system is handled by TIMOTEC**

## TECHNICAL DATA

### Panel Type

Surgical Panel

### Type

#### Upper Module

Upper Module with opening for clock

Upper Module with opening for information sign

### Material

Stainless steel AISI 304 SB grind

Galvanized steel

### Height

880 mm

### Width

500 mm

1000 mm

1500 mm

2000 mm

2500 mm

3000 mm

### Surface Treatment

#### Galvanized sheet in RAL 9016

Stainless steel sheet AISI 304

Powder coating in RAL color

Antibacterial lacquer in RAL color

### HVAC Grille Dimensions

HVAC grille with dimensions 650 mm x 650 mm

Without HVAC grille

Grille with specified dimensions

### Dimension "a"

100 mm

Without

xxx mm

### Dimension "b"

100 mm

Without

xxx mm

### Custom Version

Standard Version

Custom Version

Standard Version

0 - unambiguous specification from the offered variants

Custom Version

Q - atypical solution that cannot be unambiguously specified using the code

## MORE INFORMATION, PHOTOS

